



May 29, 2014

**ADDENDUM NO. 1**

**KIMBALL TOWER BOILER REPLACEMENT PROJECT  
CIP NO. 13-05**

The plans and specifications prepared by the Engineering Department for the City of National City entitled, "KIMBALL TOWER BOILER REPLACEMENT PROJECT", are hereby amended as follows:

1. **Section 6 – PROSECUTION , PROGRESS, AND ACCEPTANCE OF THE WORK, 6-2 PROSECUTION OF THE WORK. ADD: "Contractor shall sequence the boiler replacement such that the B-1 boiler is replaced first while the B-2 boiler is kept in place and functional. The B-1 boiler must be installed and fully functional with the water delivery system prior to replacing the B-2 boiler.**

ALL BIDDERS SHALL ACKNOWLEDGE RECEIPT AND ACCEPTANCE OF THIS ADDENDUM NO. 1 BY SIGNING IN THE SPACE PROVIDED BELOW AND RETURNING VIA EMAIL TO [JHERNANDEZ@NATIONALCITYCA.GOV](mailto:JHERNANDEZ@NATIONALCITYCA.GOV) OR BY FAX TO (619) 336-4397.

**This Addendum No. 1 must be acknowledged on Appendix 1-1 of the Bidder's Proposal and SUBMITTED WITH YOUR BID.**

**BY ORDER OF THE CITY ENGINEER OF THE CITY OF NATIONAL CITY.**

5/29/2014

Date

**Stephen Manganiello  
City Engineer**

RECEIPT ACKNOWLEDGE BY:

DATE: \_\_\_\_\_

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Print name

\_\_\_\_\_  
Company